

HILLSBOROUGH TOWNSHIP BUREAU OF FIRE SAFETY

CERTIFICATE OF SMOKE DETECTOR, CARBON MONOXIDE ALARM AND PORTABLE FIRE EXTINGUISHER COMPLIANCE (CSDCMAPFEC)

FIRE EXTINGUISHER REQUIREMENTS

FIRE EXTINGUISHER MUST BE A **MINIMUM OF 2 ½ POUNDS** MAXIMUM OF 10 POUNDS ABC TYPE

FIRE EXTINGUISHER MUST BE TAGGED AND INSPECTED BY A FIRE EXTINGUISHER INSPECTION AGENCY CERTIFIED BY THE NJ DIVISION OF FIRE SAFETY WITHIN ONE YEAR, OR HAVE A RECEIPT TAPED TO THE EXTINGUISHER SHOWING PROOF OF PURCHASE WITHIN ONE YEAR.

FIRE EXTINGUISHER MUST BE HUNG USING HANGERS, OR IN BRACKETS SUPPLIED BY THE MANUFACTURER

FIRE EXTINGUISHER MUST BE HUNG WITHIN 10 FEET OF EACH KITCHEN, IN A VISABLE, UNBLOCKED AREA, NEAR A ROOM EXIT OR TRAVEL WAY THAT PROVIDES AN ESCAPE ROUTE TO THE EXTERIOR

*****FIRE EXTINGUISHER MUST BE A-B-C. ***
IT MUST HAVE THESE SYMBOLS ON IT**



PLEASE CALL 908-369-4313 x 178 WITH ANY QUESTIONS